



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

APR 06 2004

10 CFR 50.54(f)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

In the Matter of) Docket No.50-390
Tennessee Valley Authority)

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - BULLETIN 2003-01 -
POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY SUMP
RECIRCULATION AT PRESSURIZED-WATER REACTORS - CORRECTION (TAC NO.
MB 9360)

The purpose of this letter is to correct a statement in TVA's
response to the subject bulletin for WBN dated August 8, 2003.

In the response to Item 5, "Ensuring containment drainage paths
are unblocked," third paragraph, a statement was made regarding
drains in Accumulator Rooms 3 and 4 that *"Both of these floor
drains are protected by a screened enclosure."* It was recently
identified that screens did not cover the drains in those rooms.
Upon investigation, it was determined that the screens had
previously been deleted from the plant design and were never
installed. In lieu of screens, the drains had been rerouted away
from the containment sump screens. This feature has been re-
evaluated and has been determined to remain acceptable.
Therefore, TVA does not plan to install screens over these
drains.

There are no commitments identified in this submittal. If you
have any questions concerning this correction, please contact me
at (423) 365-1824.

A103

U.S. Nuclear Regulatory Commission

Page 2

APR 06 2004

I declare under penalty of perjury that the foregoing is true and correct. Executed on this 6th day of April, 2004.

Sincerely,



P. L. Pace
Manager, Site Licensing
and Industry Affairs

cc: NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Ms. Margaret H. Chernoff, Project Manager
U.S. Nuclear Regulatory Commission
MS 08G9
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303